



# IMPORTANT HEALTH NOTICE

## Flush Your Water Line

### Six steps you should take after your lead service line is replaced

The City of Grand Rapids is replacing the water service line to your home with a new copper pipe. During construction, it is possible that some lead may have been released into the water. After your water is turned back on, it is important that you flush your water line to minimize your lead exposure. Follow these six steps to minimize your lead exposure:



**1. Remove faucet aerators.** Remove faucet aerators (screens), including showers and bathtub (see faucet illustration).



**2. Open all faucets.** Beginning in the lowest level of the home, fully open all faucets throughout your home using **cold water only**. Be sure to include bathtubs and showers (remove shower head if possible).



**3. Run water for 30 minutes.** After opening the last tap on the top floor, let the water run for **at least 30 minutes**.



**4. Close all faucets.** Turn off each faucet in the order in which you turned them on, starting with the faucets in the lowest level of the home.



**5. Clean aerators.** After flushing is complete, be sure to clean and re-install your aerators. Aerators should be cleaned every six months. For more information, please visit [Michigan.gov/mileadsafe](https://Michigan.gov/mileadsafe).

### Other Tips:

- Do not consume tap water, open hot water faucets, or use icemakers or filtered water dispensers **until after** flushing is complete.
- Once you have completed the flushing, please call 311 to inform us that you have flushed the water in your home for 30 minutes, and **you will receive** a five-unit water credit on your next utility bill.
- For more information about your water visit <https://www.grandrapidsmi.gov/Government/Departments/Water-System>.

### **6. For the next 6 months, please flush your water line every day. It's easy:**

- A five-minute "mini-flush" should be done **each morning** or if the water has not been used for six hours.
- This mini-flush is any normal water usage (shower, dishwasher, toilet flush) **other than** using water for drinking, cooking, or mixing baby formula.
- Clean aerators monthly during this six months and twice a year thereafter.



# AVISO IMPORTANTE DE SALUD

## DESCARGUE SU LINEA DE SERVICIO

### Seis pasos que debe tomar después del reemplazo de su línea de servicio de plomo

La ciudad de Grand Rapids a reemplazado su línea de servicio de agua a su casa con una línea nueva de cobre. Durante la construcción, es posible que plomo entro a su agua. Como resultado, por favor, tome los siguientes pasos para minimizar su exposición . Siga estos seis pasos para minimizar su exposición al plomo:



**1. Retire los aireadores.** Retire los aireadores de los grifos. Incluso las duchas o bañeras (ve la ilustración a la izquierda).



**2. Abre todos los grifos.** Comenzando en el nivel más bajo de la casa, abre completamente todos los grifos usando **agua fría solamente**. Asegúrese de incluir bañeras y duchas.



**3. Corre el agua por 30 minutos.** Después de abrir el última grifo, deje correr el agua en todos los grifos por 30 minutos.



**4. Cierre todos los grifos.** Cierre cada grifo en el orden en que los abrió empezando con los grifos en el nivel más bajo de la casa .



**5. Limpie y reemplace los aireadores.** Después de que el descargo se ha completado, limpie y reinstale los aireadores. Los aireadores deben de ser limpiados cada seis meses. Para más información, por favor visite [Michigan.gov/mileadsafe](http://Michigan.gov/mileadsafe).

### Otros Consejos:

- No tome agua del grifo caliente, use máquinas de hielo o dispensadores de agua filtrada **hasta después** del que descargue se ha completado.
- Cuando haya terminado el descargo de la línea de agua, llame al 311 o 616.456.3000 infórmenos que ha descargado el agua de servicio en su casa por 30 minutos y que quieres tu cuenta acreditada. **Recibiera un crédito** de agua de cinco unidades en su próxima factura de utilidades.
- Para mas información visite [www.grandrapidsmi.gov/Government/Departments/Water-System](http://www.grandrapidsmi.gov/Government/Departments/Water-System).

### 6. En los próximos seis meses, descargue su línea de servicio cada día. Es fácil:

- Descargue su línea de servicio por cinco minutos **cada mañana** o si no ha sido usada por seis horas.
- Este descargue puede ser, dejando correr la bañera, lavaplatos o tasa de bajo, **pero no para tomar, cocinar o mezclar formula de bebe.**
- Limpié los aireadores cada seis meses y dos veces al año.