

CLIENT:	Grand Rapids Water Department	Collection Date	4/8/2026 9:30:00 AM
Project:	Quarterly PFAS (WSSN MI0002790)	Received Date:	4/8/2026 11:00:00 AM
Lab ID:	2604638-01	Matrix:	DRINKING WATER
Client Sample ID:	E. Tap (TP100)	Sampled By:	S. Vandenberg
Location:		TAG No:	

Analyses	Result	RL	Qual	Units	MCL	Date Analyzed
----------	--------	----	------	-------	-----	---------------

PFAS, DRINKING WATER

EPA 537.1

Analyst: JS

PFBS	< 2.0	2.0		ng/L		4/16/2026 3:19:00 AM
PFHxA	< 2.0	2.0		ng/L		4/16/2026 3:19:00 AM
HFPO-DA	< 2.0	2.0		ng/L	10	4/16/2026 3:19:00 AM
PFHxS	< 2.0	2.0		ng/L	10	4/16/2026 3:19:00 AM
PFHpA	< 2.0	2.0		ng/L		4/16/2026 3:19:00 AM
ADONA	< 2.0	2.0		ng/L		4/16/2026 3:19:00 AM
PFOA	< 2.0	2.0		ng/L	4.0	4/16/2026 3:19:00 AM
PFOS	2.5	2.0		ng/L	4.0	4/16/2026 3:19:00 AM
PFNA	< 2.0	2.0		ng/L	10	4/16/2026 3:19:00 AM
9Cl-PF3ONS	< 2.0	2.0		ng/L		4/16/2026 3:19:00 AM
PFDA	< 2.0	2.0		ng/L		4/16/2026 3:19:00 AM
NMeFOSAA	< 2.0	2.0		ng/L		4/16/2026 3:19:00 AM
NEtFOSAA	< 2.0	2.0		ng/L		4/16/2026 3:19:00 AM
PFUnA	< 2.0	2.0		ng/L		4/16/2026 3:19:00 AM
11Cl-PF3OUdS	< 2.0	2.0		ng/L		4/16/2026 3:19:00 AM
PFDoA	< 2.0	2.0		ng/L		4/16/2026 3:19:00 AM
PFTTrDA	< 2.0	2.0		ng/L		4/16/2026 3:19:00 AM
PFTA	< 2.0	2.0		ng/L		4/16/2026 3:19:00 AM
PFAS Hazard Index	< 0.18	0.18		ng/L	1.0	4/16/2026 3:19:00 AM
Surr: d5-N-EtFOSAA	80.4	70 - 130		%Rec		4/16/2026 3:19:00 AM
Surr: M3HFPO-DA	76.7	70 - 130		%Rec		4/16/2026 3:19:00 AM
Surr: MPFDA	107	70 - 130		%Rec		4/16/2026 3:19:00 AM
Surr: MPFHxA	86.2	70 - 130		%Rec		4/16/2026 3:19:00 AM

Qualifiers: < Not Detected at the Reporting Limit
MCL Maximum Contaminant Level
RL Reporting Limit

H Holding times for preparation or analysis exceeded
PL Permit Limit
S Spike Recovery outside accepted recovery limits

CLIENT:	Grand Rapids Water Department	Collection Date	4/8/2026 9:27:00 AM
Project:	Quarterly PFAS (WSSN MI0002790)	Received Date:	4/8/2026 11:00:00 AM
Lab ID:	2604638-02	Matrix:	BLANK
Client Sample ID:	FRB	Sampled By:	S. Vandenberg
Location:		TAG No:	

Analyses	Result	RL	Qual	Units	MCL	Date Analyzed
----------	--------	----	------	-------	-----	---------------

PFAS, DRINKING WATER

EPA 537.1

Analyst: JS

PFBS	< 2.0	2.0		ng/L		4/16/2026 1:22:00 AM
PFHxA	< 2.0	2.0		ng/L		4/16/2026 1:22:00 AM
HFPO-DA	< 2.0	2.0		ng/L	10	4/16/2026 1:22:00 AM
PFHxS	< 2.0	2.0		ng/L	10	4/16/2026 1:22:00 AM
PFHpA	< 2.0	2.0		ng/L		4/16/2026 1:22:00 AM
ADONA	< 2.0	2.0		ng/L		4/16/2026 1:22:00 AM
PFOA	< 2.0	2.0		ng/L	4.0	4/16/2026 1:22:00 AM
PFOS	< 2.0	2.0		ng/L	4.0	4/16/2026 1:22:00 AM
PFNA	< 2.0	2.0		ng/L	10	4/16/2026 1:22:00 AM
9CI-PF3ONS	< 2.0	2.0		ng/L		4/16/2026 1:22:00 AM
PFDA	< 2.0	2.0		ng/L		4/16/2026 1:22:00 AM
NMeFOSAA	< 2.0	2.0		ng/L		4/16/2026 1:22:00 AM
NEtFOSAA	< 2.0	2.0		ng/L		4/16/2026 1:22:00 AM
PFUnA	< 2.0	2.0		ng/L		4/16/2026 1:22:00 AM
11CI-PF3OUdS	< 2.0	2.0		ng/L		4/16/2026 1:22:00 AM
PFDaA	< 2.0	2.0		ng/L		4/16/2026 1:22:00 AM
PFTTrDA	< 2.0	2.0		ng/L		4/16/2026 1:22:00 AM
PFTA	< 2.0	2.0		ng/L		4/16/2026 1:22:00 AM
Surr: d5-N-EtFOSAA	80.2	70 - 130		%Rec		4/16/2026 1:22:00 AM
Surr: M3HFPO-DA	87.6	70 - 130		%Rec		4/16/2026 1:22:00 AM
Surr: MPFDA	95.1	70 - 130		%Rec		4/16/2026 1:22:00 AM
Surr: MPFHxA	84.6	70 - 130		%Rec		4/16/2026 1:22:00 AM

Qualifiers: < Not Detected at the Reporting Limit
MCL Maximum Contaminant Level
RL Reporting Limit

H Holding times for preparation or analysis exceeded
PL Permit Limit
S Spike Recovery outside accepted recovery limits