

CLIENT: Grand Rapids Water Department
Project: Quarterly PFAS (WSSN MI0002790)

Lab Order: 2607444

Lab ID: 2607444-01 **Matrix:** DRINKING WATER **Collection Date:** 7/7/2026 9:45:00 AM
Client ID: E. Tap (TP100) **Sampler:** Z. Elliott **Received Date:** 7/7/2026 11:25:00 AM
Location:

Analyses	Result	RL	Qual	Units	MCL	Date Analyzed
PFAS, DRINKING WATER				EPA 537.1		Analyst: JS
PFBS	< 2.0	2.0		ng/L	420	7/11/2026 2:40:00 AM
PFHxA	< 2.0	2.0		ng/L	400000	7/11/2026 2:40:00 AM
HFPO-DA	< 2.0	2.0		ng/L	370	7/11/2026 2:40:00 AM
PFHxS	< 2.0	2.0		ng/L	51	7/11/2026 2:40:00 AM
PFHpA	< 2.0	2.0		ng/L		7/11/2026 2:40:00 AM
ADONA	< 2.0	2.0		ng/L		7/11/2026 2:40:00 AM
PFOA	2.2	2.0		ng/L	8.0	7/11/2026 2:40:00 AM
PFOS	2.4	2.0		ng/L	16	7/11/2026 2:40:00 AM
PFNA	< 2.0	2.0		ng/L		7/11/2026 2:40:00 AM
9Cl-PF3ONS	< 2.0	2.0		ng/L	6.0	7/11/2026 2:40:00 AM
PFDA	< 2.0	2.0		ng/L		7/11/2026 2:40:00 AM
NMeFOSAA	< 2.0	2.0		ng/L		7/11/2026 2:40:00 AM
NEtFOSAA	< 2.0	2.0		ng/L		7/11/2026 2:40:00 AM
PFUnA	< 2.0	2.0		ng/L		7/11/2026 2:40:00 AM
11Cl-PF3OUdS	< 2.0	2.0		ng/L		7/11/2026 2:40:00 AM
PFDoA	< 2.0	2.0		ng/L		7/11/2026 2:40:00 AM
PFTTrDA	< 2.0	2.0		ng/L		7/11/2026 2:40:00 AM
PFTA	< 2.0	2.0		ng/L		7/11/2026 2:40:00 AM
Surr: d5-N-EtFOSAA	77.9	70 - 130		%Rec		7/11/2026 2:40:00 AM
Surr: M3HFPO-DA	99.7	70 - 130		%Rec		7/11/2026 2:40:00 AM
Surr: MPFDA	92.0	70 - 130		%Rec		7/11/2026 2:40:00 AM
Surr: MPFHxA	94.5	70 - 130		%Rec		7/11/2026 2:40:00 AM

Qualifiers:
< Not Detected at the Reporting Limit
MCL Maximum Contaminant Level
RL Reporting Limit

H Holding times for preparation or analysis exceeded
PL Permit Limit
S Spike Recovery outside accepted recovery limits

Original
Page 2 of 4

CLIENT: Grand Rapids Water Department
Project: Quarterly PFAS (WSSN MI0002790)

Lab Order: 2607444

Lab ID: 2607444-02

Matrix: BLANK

Collection Date: 7/7/2026 9:40:00 AM

Client ID: FRB

Sampler: Z. Elliott

Received Date: 7/7/2026 11:25:00 AM

Location:

Analyses	Result	RL	Qual	Units	MCL	Date Analyzed
PFAS, DRINKING WATER				EPA 537.1		Analyst: JS
PFBS	< 2.0	2.0		ng/L	420	7/10/2026 9:46:00 PM
PFHxA	< 2.0	2.0		ng/L	400000	7/10/2026 9:46:00 PM
HFPO-DA	< 2.0	2.0		ng/L	370	7/10/2026 9:46:00 PM
PFHxS	< 2.0	2.0		ng/L	51	7/10/2026 9:46:00 PM
PFHpA	< 2.0	2.0		ng/L		7/10/2026 9:46:00 PM
ADONA	< 2.0	2.0		ng/L		7/10/2026 9:46:00 PM
PFOA	< 2.0	2.0		ng/L	8.0	7/10/2026 9:46:00 PM
PFOS	< 2.0	2.0		ng/L	16	7/10/2026 9:46:00 PM
PFNA	< 2.0	2.0		ng/L	6.0	7/10/2026 9:46:00 PM
9Cl-PF3ONS	< 2.0	2.0		ng/L		7/10/2026 9:46:00 PM
PFDA	< 2.0	2.0		ng/L		7/10/2026 9:46:00 PM
NMeFOSAA	< 2.0	2.0		ng/L		7/10/2026 9:46:00 PM
NEtFOSAA	< 2.0	2.0		ng/L		7/10/2026 9:46:00 PM
PFUnA	< 2.0	2.0		ng/L		7/10/2026 9:46:00 PM
11Cl-PF3OUdS	< 2.0	2.0		ng/L		7/10/2026 9:46:00 PM
PFDoA	< 2.0	2.0		ng/L		7/10/2026 9:46:00 PM
PFTTrDA	< 2.0	2.0		ng/L		7/10/2026 9:46:00 PM
PFTA	< 2.0	2.0		ng/L		7/10/2026 9:46:00 PM
Surr: d5-N-EtFOSAA	75.6	70 - 130		%Rec		7/10/2026 9:46:00 PM
Surr: M3HFPO-DA	82.3	70 - 130		%Rec		7/10/2026 9:46:00 PM
Surr: MPFDA	91.2	70 - 130		%Rec		7/10/2026 9:46:00 PM
Surr: MPFHxA	81.9	70 - 130		%Rec		7/10/2026 9:46:00 PM

Qualifiers: < Not Detected at the Reporting Limit
MCL Maximum Contaminant Level
RL Reporting Limit

H Holding times for preparation or analysis exceeded
PL Permit Limit
S Spike Recovery outside accepted recovery limits

Original
Page 3 of 4